

SPECIFICATION



EV1 Standard Capacity Card Lift Access



EV1 MAG Standard Lift Access Control Package

General Description

Authorized floor for each user is programmed into the reader through MagEtegra ME-ACS software. Support up to **1024 cards** and **16 floors (max 32 floors)**. Add MAC416 to support additional 16 floors. Operator can specify when **(time zone)**, which floor **(floor group)** and which elevator **(door group)** user can access.

Users get into lift car and flashes the card to the reader installed beside the floor buttons. User is only allowed to select floor that is authorized for his access. Building manager will be able to control, monitor and generate access **log daily, monthly and yearly report from PC**.

Application

Elevator access control system for condominium for a better security to block entry of intruder. Building offices to control employees on which floor employees can access, etc.

Ordering information

Model: EV1

Qty	Parts
1 pcs	AR721H V3 lift access interface
1 pcs	AR721U wiegand reader
1 pcs	MAC416 16 relay output interface
1 pcs	AR321L485 interface
2 pcs	MAG Metal box w/ cam-lock (build-in power supply w/ indicator)
2 pcs	Key switch (latch type) on/off
1 pcs	Key switch stainless steel plate
2 pcs	2.2K ohm resistor
2 pcs	120 ohm resistor
1 pcs	Protection fuse
2 pcs	12V DC Relay with base


Further Upgrade Recommendation via:

- Add AR727CM to connect to TCPIP network with IP address for PC software management. Each AR727CM can support 2 set EV1.
- Add MAC416 to support additional 16 floors. Each EV1 can support maximum 32 floors (2 x MAC416).
- Use RS422 data cable with shielding for RS485 and Wiegand data running. CAT5 or CAT6 is not suitable for wiring inside lift.
- Use MagEtegra Pro-Basic (SEPB) for multiple EV1 over TCPIP LAN network.


****Please consult our technical specialist for more information on proper wiring to ensure no data loss over long distance.**

Connection Architecture

Standard Installation Setup



Multi-System Deployment



© COPYRIGHT 2026. This documentation served as a reference only. It is subject to change without further notice. All the diagrams and information in this documentation may not be duplicated or modified in any form without the written approval from the management.